

WATER QUALITY TESTING REPORT
Source: - Govt. Secondary School Kombo
Date of testing: - 05/10/2026

Sl no.	Parameter	Range	Report/ Result
1.	Turbidity	0-100 NTU	0.7 NTU
2.	PH	6.5 to 8.5 value	7.2 Value
3.	Total Alkalinity	0-500 mg/l	42 mg/l
4.	Chloride	0-50mg/l	4 mg/l
5.	Chlorine	0-5 mg/l	0.001 mg/l
6.	Fluoride	0-1.5 mg/l	0.001 mg/l
7.	Total Hardness	0-500 mg/l	15 mg/l
8.	Iron	0-1mg/l	0.001 mg/l
9.	Nitrate	0-1ml/l	0.002 mg/l
10.	Bacteriological	Present/ Absent	Absent


Lab Asstt.
PHE & W/S Division
Aalo.


Asstt. Survy. of Works
PHED Aalo